

# CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

FLO-21-03-18-02

**Product:** Kastamonu Laminate Flooring 12 mm AC4 / AC5  
Surface structure: AUTHENTIC

**Producer:** Kastamonu Entegre Ağaç Sanayi ve Ticaret A.Ş.  
Hacı Sabancı O.S.B Cela  
Bayar Bulvarı No: 21  
Sarıçam / ADANA / 01250  
TURKEY

**Order:** Testing of selected properties according to according to  
EN 14041:2004+AC:2005+AC:2006 (CE-labelling)

**Test report:** 2721111


**Test results:** *The above mentioned Laminate Flooring can be classified regarding to the tested properties according to EN 14041:2004+AC:2005+AC:2006 (CE-labelling) as follows:*

Property	Result	Declaration according to EN 14041:2004+AC:2005+AC:2006
Sliding behaviour according to EN 13893:2002-11	$\mu = 0.51$	class DS
Thermal resistance according to EN 12667:2001-01	0.0803 (m <sup>2</sup> K)/W	0.080 (m <sup>2</sup> K)/W

Dresden, 18/03/2021



Head of laboratory

Engineer in charge