

# TEST CERTIFICATE

ST-21-03-18-01

**Product:** Kastamonu Laminate Flooring 8 mm AC4 / AC5

**Producer:** Kastamonu Entegre Ağaç Sanayi ve Ticaret A.Ş.  
Hacı Sabancı O.S.B Cela  
Bayar Bulvarı No: 21  
Sarıçam / ADANA / 01250  
TURKEY

**Order:** Determination of the impact sound reduction  
according to EN ISO 10140-3:2010 + A1:2015-06/ EN ISO 717-2:2013-03

**Test report:** 2721111

**Test result:**


Property	Result	Declaration of impact sound reduction
Impact sound reduction according to EN ISO 10140-3:2010 + A1:2015-06/ EN ISO 717-2:2013-03	$\Delta L_w = 15 \text{ dB}$	15 dB

Dresden, 18/03/2021



Head of laboratory





Engineer in charge