

# TEST CERTIFICATE

ST-21-04-16-01

**Product:** Kastamonu - 8 mm Laminate Flooring

**Producer:** Kastamonu Entegre Agaç San.Tic.A.S  
Inebolu Yolu üzeri 18. Km Org. San. Böl.  
37200 HALIFE KÖYÜ/KASTAMONU  
TURKEY

**Order:** Determination of the impact sound reduction  
according to EN ISO 10140-3:2010 + A1:2015-06/ EN ISO 717-2:2013-03

**Test report:** 2721071

**Test result:**


Property	Result	Declaration of impact sound reduction
Impact sound reduction according to EN ISO 10140-3:2010 + A1:2015-06/ EN ISO 717-2:2013-03	$\Delta L_w = 13$ dB	13 dB

Dresden, 16/04/2021



Head of laboratory





Engineer in charge