

# CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

FLO-21-04-16-01


- Product:** Kastamonu - 8 mm Laminate Flooring  
Surface structure: Timberland  
Dimension: 1205 mm x 197 mm x 8 mm
- Producer:** Kastamonu Entegre Ağaç San.Tic.A.Ş  
İnebolu Yolu üzeri 18. Km Org. San. Böl.  
37200 HALİFE KÖYÜ/KASTAMONU  
TURKEY
- Order:** Testing of selected properties according to according to  
EN 14041:2004+AC:2005+AC:2006 (CE-labelling)
- Test report:** 2721071
- Test results:** *The above mentioned Laminate Flooring can be classified regarding to the tested properties according to EN 14041:2004+AC:2005+AC:2006 (CE-labelling) as follows:*

Property	Result	Declaration according to EN 14041:2004+AC:2005+AC:2006
Sliding behaviour according to EN 13893:2002-11	$\mu = 0.52$	class DS
Thermal resistance according to EN 12667:2001-01	0.0477 (m <sup>2</sup> K)/W	0.048 (m <sup>2</sup> K)/W

Dresden, 16/04/2021



Head of laboratory

Engineer in charge