

# CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

FLO-23-04-05-01

- Product:** "Kastamonu Laminate Flooring  
(all decors, unicolors and designs)"  
Thickness: 8 mm
- Producer:** Kastamonu Entegre Ağaç San. Tic. A.Ş.  
Yeditepe Tek. Üssü İç Kapı No:Z02  
Pendik, Istanbul  
Türkiye
- Order:** Determination of the electrostatic behaviour according to EN 1815:2016-09 /  
Classification according to EN 14041:2004+AC:2005+AC:2006
- Test report:** 2723135\_A1 (tested Variant 2)


**Test result:**

Property	Determined Values	Declaration according to EN 14041:2004+AC:2005+AC:2006
Body voltage in walking test according to EN 1815:2016-09	BV = 0,9 kV	Antistatic Floor Covering

Dresden, 05/04/2023



Head of laboratory

Engineer in charge